



E2.10 Scale 1/8"=1'-0'

N	POWER PACK, WIRELESS, 120/277 V, 0-10 V DIMMING CONTROL, PROVIDE JUNCTION BOX TO MOUNT POWER PACK, ROUTE #18 AWG, SOLID CU CONDUCTORS TO LUMINAIRES IN SPACE, CONNECT COMPLETE. COORDINATE WITH INSTALLATION DRAWINGS PRIOR TO ROUGH-IN
RP N	POWER PACK, WIRELESS, 120/277 V, RELAY CONTROL, PROVIDE JUNCTION BOX TO MOUNT POWER PACK, ROUTE CONDUCTORS TO DEVICES TO BE CONTROLLED. PROVIDE ADDITIONAL UN-SWITCHED CONDUCTOR FOR NON-SWITCHED DEVICES, CONNECT COMPLETE. COORDINATE WITH INSTALLATION DRAWINGS PRIOR TO ROUGH-IN
	WIRELESS CEILING MOUNTED OCCUPANCY / VACANCY SENSOR, SET PER SEQUENCE OF PERATIONS, PASSIVE INFRARED MOTION DETECTION, CONNECT COMPLETE. COORDINATE WITH INSTALLATION DRAWINGS PRIOR TO ROUGH-IN
	WIRELESS CEILING MOUNTED DAYLIGHT SENSOR, CONNECT COMPLETE. COORDINATE LOCATION WITH INSTALLATION DRAWINGS PRIOR TO ROUGH-IN
\$ND	WIRELESS WALL DIMMING SWITCH, CONNECT COMPLETE. VERIFY BUTTON MARKING WITH OWNER, CONNECT COMPLETE. COORDINATE WITH INSTALLATION DRAWINGS PRIOR TO ROUGH-IN

