

② FIRE LANE
 Curbs to be painted red
 3.5" min. ht. block white Lettering to be
 on face of curb with a min. 0.5" stroke


Curbs to be painted red
 3.5" min. ht. block white Lettering to be
 on face of curb with a min. 0.5" stroke

KEY NOTES

- ① Fire Hydrant Locations
- ② Fire lane marking locations
- ③ No vehicle gate locations on site
- ④ Fire Department Connection location
- ⑤ Sprinkler Riser Location
- ⑥ No fire-pump location on site
- ⑦ Fire Alarm Panel location
- ⑧ Electrical room
- ⑨ Electrical Meters
- ⑩ Mechanical room
- ⑪ Knox Box location
- ⑫ Roof access
- ⑬ No Standpipes or floor control valves
- ⑭ No Fire Access Doors
- ⑮ No Emergency Standby power generator on site
- ⑯ No Hazardous materials stored on site
- ⑰ No Fire Command Center location noted
- ⑱ PUD lock box

- ⑳ Exit Light
- ㉑ Fire Extinguisher Cabinet
- ㉒ EVAC sign
- ㉓ Emergency back up light

REVISED
 8:45 am, Jan 22, 2024



LEEKA Architecture and Planning
 Creating Positive Impressions in the Built Environment
 503.844.4222 | lee@leeka.com
 1001 SE Water Avenue Suite 175
 Portland, Oregon 97214
 www.leeka.com | web

**Tenant Improvement
 Educational Service District 112
 Mental Health Facility Phase II**
 2400 NE 65th Ave. Vancouver, WA.

Revised:	DATE: Aug. 10, 2023
△ PCR 01	DATE: Aug. 17, 2023
△ APPLICANT EDITS	DATE: Sept. 22, 2023
△ APPLICANT EDITS	DATE: Oct. 03, 2023
△ APPLICANT EDITS	DATE: Oct. 03, 2023
△ APPLICANT EDITS	DATE: Oct. 03, 2023

Job No:	2246
Date:	26-Dec-23
File Size:	24x36
Permit Application	
DRAWN:	NYL
CHECKED:	NYL
Sheet Title	Fire Response Site Plan
Sheet Number	A1.10

