

ADDENDUM No. 01

SUBJECT Clarifications

DATE ISSUED October 3, 2023

- Include both faced and unfaced batts per the plans and specifications.
- All interior insulation to be “mineral wool” type only.
- Include vapor barrier per the plans.
- Include all ceiling insulation to also be faced with “white” fire-proof vinyl sheet.
- All newly framed walls and ceilings that are a part of this project will be insulated. Leave no portions undone.
- Include a Tyvek vapor barrier on the new mezzanine decking to match existing mezzanine from phase 1.

Important Note to Bidders:

Only the items referenced in this addendum shall be revised. All other provisions, requirements, and terms and conditions of ITB ESD 112-16-23 shall remain the same.

Instructions to Bidders:

Bidders shall sign, date and submit the form on this page with the rest of your company’s bid materials.

Name of Company _____

Name of Authorized Representative (Please print) _____

Signature of Authorized Representative _____

Date Signed _____

Thank you.



Jeff Strunk, Director of Purchasing & Facilities
E-Mail: Jeff.Strunk@esd112.org