
ADDENDUM No. 03

SUBJECT Questions and Answers

DATE ISSUED October 19, 2023

1. E2.00 Demo plan shows panels to be removed and one-line not showing. Do you know feeder raceway and wire size?
 - a. **Per 26 00 00 specifications contractor is responsible for visiting the site prior to bid and verify existing conditions.**
The following is site observations only and does not alleviate the contractor's responsibility to visit the site to verify existing conditions, as no record drawings were available.
 - i. Existing panel, grid 5A, 200 amp, 2"C
 - ii. Existing panel, grid 5B-C, 200 amp, 2"C
 - iii. Existing panel, grid 9B, 100 amp, 1-2"C
2. E3.10 is not showing location of new panels HA, LA and 45kva transformer, I assume there going in the Electric Rm 111.
 - a. **Panel are shown on E3.20, Floor Plan Equipment, located in Utility Room, 120 (grid 5A)**
3. Drawings are showing existing panel- XFMR and a panel or disconnect that appears to be remaining in place.
 - a. **That is correct, Distribution Equipment shown, Electrical Room 111, serves a tenant space east of grid line 9 and can not be used as part of phase II scope of work.**
4. E4.00 one-line; Panels HA, LA and 45kva XFMR the only new install? Please verify that the existing 2-150KVA XFMR's and panel H1 require no work to scope, confused on the feeder schedule noted but equipment is noted as existing?
 - a. **Correct, "Existing to Remain" are noted with E in a hex note.**
Panels HA, LA, LB and 75 kva Xfrmr are new and part of scope of work.
Please request updated electrical plans as it appears that PECl does not have the current revised construction documents.

Please be sure you are referring to the construction drawings that were posted on our site on October 10: <https://www.esd112.org/news/faq-items/electrical-2400-phase-ii/>

All addenda are also posted to that location.

Important Note to Bidders:

Only the items referenced in this addendum shall be revised. All other provisions, requirements, and terms and conditions of ITB ESD 112-13-23 shall remain the same.

Instructions to Bidders:

Bidders shall sign, date and submit the form on this page with the rest of your company's bid materials.

Name of Company _____

Name of Authorized Representative (Please print) _____

Signature of Authorized Representative _____

Date Signed _____

Thank you.



Jeff Strunk, Director of Purchasing & Facilities
E-Mail: Jeff.Strunk@esd112.org